

13 NOV 2025 TE ELECTRICAL SEM-V C SCHEME EPS-II QP CODE: 10095593

Duration : 03 hrs**Maximum Marks = 80****NOTE**

1. Question No 1 is Compulsory.
2. Attempt any three questions out of the remaining five questions.
3. Assume the suitable data if necessary and justify the same.

Question no.	Question	Marks
Q.1 A	Explain the terms short circuit MVA and symmetrical fault.	05
Q.1 B	Describe the volt time curve as required for insulation coordination studies in power system with an example	05
Q.1 C	Discuss in brief the significance of tower footing resistance	05
Q.1 D	Describe the working principle of lightning arrester. Explain any arrester in detail.	05
Q.2 A	Illustrate the short circuit of a synchronous machine at no load condition.	10
Q.2 B	Build the Z-bus for the 3 Bus network in which elements are connected as Bus 1-Bus 2: $j0.2$; Bus 1-Bus 2: $j0.4$; Bus 1-Bus3: $j0.35$ Bus 2-Bus 3: $j0.25$. (Assume Bus 3 as a reference bus)	10
Q.3 A	Explain and draw the zero sequence networks for following types of connections of a three phase transformer i) Delta-Delta ii) Delta-Star(ungrounded) iii) Delta-Star(Grounded) iv) Star(Grounded)- Star(Grounded) v) Star(ungrounded)- Star(ungrounded)	10
Q.3 B	Derive the equation for fault current and sequence network for single line to ground fault. State the various assumptions in derivation.	10
Q.4 A	A star connected balanced load of 10ohm each has the following voltages across its terminals $V_{ab}=200V$, $V_{bc}=220V$ and $V_{ca}=180V$. Calculate the symmetrical components of line and phase voltages. From the symmetrical components of line voltages determine the line current.	10
Q.4 B	Describe the generation of voltage and current travelling waves on a short circuited line with figure and equations.	10

95593**Page 1 of 2**

- Q.5 A Explain the principle of lightning phenomenon and protection against lightning with respect to the power system. **10**
- Q.5 B Discuss the advantages and disadvantages of Corona **10**
- Q.6 A Describe the Z-bus formulation. **10**
- Q.6 B Explain the following (i) critical disruptive voltage and visual disruptive voltage (ii) transient recovery voltage **10**
